



# **iJRASET**

International Journal For Research in  
Applied Science and Engineering Technology



---

# **INTERNATIONAL JOURNAL FOR RESEARCH**

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

---

**Volume: 4**

**Issue: III**

**Month of publication: March 2016**

**DOI:**

**[www.ijraset.com](http://www.ijraset.com)**

**Call: ☎ 08813907089**

**E-mail ID: [ijraset@gmail.com](mailto:ijraset@gmail.com)**

# Enhancement of Power Quality in Distribution System Using D-STATCOM

Mr.M.Kamalakkannun<sup>1</sup>, Mr.P.Arulkumar<sup>2</sup>, D. Jasmine Susila<sup>3</sup>  
<sup>1,2,3</sup> PRIST University, Puducherry, India

**Abstract:** Sensitive loads are greatly affected by power-quality (PQ) disturbances in the system. Power quality problems such as voltage sag and harmonic distortion along with reliability issues are some major concern and in this work the voltage distortion & reactive power issues are considered. Inverters based on Voltage Source Converters (VSC) are widely used as a basic component in custom power devices. These controllers produce voltage harmonics due to switching operation of power electronic converters. The proposed controller supplements the voltage-sag compensation control of the statcom. It does not require phase-locked loop and independently controls the magnitude and phase angle of the injected voltage for each phase.

The proposed scheme have the following advantages such as limit the fault current, interrupt the fault current within two cycles, interrupt the fault current during arcing fault and low dc link voltage. The circuit will be simulated using MATLAB.

**Index Terms:** Voltage Source Converters (VSC), power-quality (PQ), STATCOM..

## I. INTRODUCTION

The ongoing expansion and growth of the electric utility industry continuously introduce changes to a once predictable business. Electricity is increasingly being considered and handled as a commodity. Thus transmission systems are being pushed closer to their stability and thermal limits with the focus on the quality of power delivered. In the evolving utility environment, financial and market forces will continue to demand a more optimal and profitable operation of the power system with respect to generation, transmission and distribution. Advanced technologies are paramount for the reliable and secure operation of power systems. To achieve both operational reliability and financial profitability it is clear that more efficient utilization and control of the existing transmission system infrastructure is required.

Improved utilization of the existing power system is provided through the application of advanced control technologies. Power electronics based equipment or Flexible AC Transmission systems (FACTS) provide proven technical solutions to address these new operating challenges being presented today. FACTS technologies allow for improved transmission system operation with minimal infrastructure investment, environmental impact and implementation time compared to the construction of new transmission lines. FACTS technologies provide advanced solutions as cost effective alternative to new transmission line construction. FACTS provide the needed corrections of transmission functions in order to efficiently utilize existing transmission systems and therefore, minimize the gap between the stability and the thermal level.




Figure 1: Voltage Fluctuation Mitigation with STATCOM

## II. TRADITIONAL SOURCE INVERTERS

Traditional source inverters are Voltage Source Inverter and Current Source Inverter. The input of Voltage Source Inverter is a stiff dc voltage supply, which can be a battery or a controlled rectifier both single phase and three phase voltage source inverter are used

## International Journal for Research in Applied Science & Engineering Technology (IJRASET)

in industry. The switching device can be a conventional MOSFET, Thyristor, or a power transistor. Voltage source inverter is one which the dc source has small or negligible impedance. In other words a voltage source inverter has stiff dc source voltage at its input terminals. A current-fed inverter or current source inverter is fed with adjustable current source. In current source inverter output current waves are not affected by the load.

### A. Voltage Source Inverter

When the power requirement is high, three phase inverters are used. When three single-phase inverters are connected in parallel, we can get the three-phase inverter. The gating signals for the three phase inverters have a phase difference of  $120^\circ$ . These inverters take their dc supply from a battery or from a rectifier and can be called as six-step bridge inverter. Figure.2.2 shows the three phase inverter using six MOSFET's and with diodes. A large capacitor is connected at the input terminals tends to make the input dc voltage constant. This capacitor also suppresses the harmonics fed back to the source. Therefore the Voltage Source Inverter is only buck (step down) inverter operation for DC to AC power conversion or boost (step-up) operation for AC to DC power conversion.




Figure.2 Voltage Source Inverter

For applications where over drive is desirable and the available dc voltage is limited, an additional dc-dc boost converter is needed to obtain a desired ac output. The additional power converter stage increases system cost and lowers efficiency. The upper and lower devices of each phase leg cannot be gate on simultaneously either by purpose or by EMI noise. Otherwise a shoot through problem by Electromagnetic interference noise's misgating-on is major killer to the inverter reliability. Dead time to block both upper and lower devices has to provide in the Voltage Source Inverter which causes the waveform distortion, etc. An output LC filters needed for providing a sinusoidal voltage compared with Current Source Inverter which causes additional power loss and control complexity.

## III. OPERATION

### A. Modes of Operation

Three phase inverters are normally used for high power applications. Three single-phase half or full bridge inverters can be connected in parallel to form the configuration of a three phase inverter. The gating signals of single phase inverters should be advanced or delayed by  $120^\circ$  with respect to each other in order to obtain three phase balanced voltages. The three phase output can be obtained from a configuration of six switches and six diodes. Two types of control signals can be applied to the switches:  $180^\circ$  conduction or  $120^\circ$  conduction.

*1)  $180^\circ$  Conduction:* Each switch conducts for  $180^\circ$ . Three switches remain on at any instant of time. When switch 1 is switched on, terminal 'a' is connected to the positive terminal of the dc input voltage. When switch 4 is switched on, terminal 'a' is connected to the negative terminal of the dc source. There are six modes of operation in a cycle and the duration of each mode is  $60^\circ$ . The switches are numbered in the sequence of gating the switches 123, 234, 345, 456, 561, 612. The gating signals are shifted from each

During mode 1 for  $0 \leq \omega t \leq \pi/3$  switches 1 and 6 conducts.


During mode 2 for  $\pi/3 \leq \omega t \leq 2\pi/3$ , switches 1 and 2 conduct.

During mode 3 for  $2\pi/3 \leq \omega t \leq 3\pi/3$ , switches 2 and 3 conduct.

The line to neutral voltages can be expressed in Fourier series as given in equations 2.1 to 2.3.

$$V_{bn} = n=1, 3, 5 \dots \Sigma \infty 2V_s/n\pi \cos n\pi/6 \sin n(\omega t - \pi/2) \quad \dots 2.2$$

$$V_{cn} = n=1, 3, 5 \dots \sum_{\infty} 2V_s/n\pi \cos n\pi/6 \sin n(\omega t - 7\pi/6) \quad \dots 2.3$$



## International Journal for Research in Applied Science & Engineering Technology (IJRASET)

The a to b line voltage is  $V_{ab} = \sqrt{3} V_{an}$  with a phase advance of  $30^\circ$ . There is a delay of  $\pi/6$  between the turning off switch 1 and turning on of switch 4. Thus there should be no short circuit of the dc supply through one upper and lower switch. At any time, two load terminals are connected to the dc supply and the third one remains open. The potential of this open terminal will depend on the load characteristics and would be unpredictable. Since one switch conducts for  $120^\circ$ , the switches are less utilized as compared to that of  $180^\circ$  conduction for the load condition. The control of output voltage is done using pulse width modulation. The commonly used techniques are Single pulse width modulation.

Multiple pulse width modulation.

Sinusoidal pulse width modulation.

Modified sinusoidal pulse width modulation.

Phase displacement control.

3) *Pulse Width Modulation Technique*: The control of output voltage is done using pulse width modulation. The commonly used techniques are

Single pulse width modulation.

Multiple pulse width modulation.

Sinusoidal pulse width modulation.

Modified sinusoidal pulse width modulation.

Phase displacement control.

**Pulse-width modulation (PWM)** is a very efficient way of providing intermediate amounts of electrical power between fully on and fully off. A simple power switch with a typical power source provides full power only when switched on. PWM is a comparatively recent technique, made practical by modern electronic power switches.

### IV. SIMULATION MODELS

#### A. Case-1 STATCOM




Figure.4 Circuit diagram

# International Journal for Research in Applied Science & Engineering Technology (IJRASET)




Figure.5 Three phase load voltage (RMS)




Figure.6 FFT analysis

## B. Case-2 D-STATCOM




Figure.7 Circuit diagram with D- STATCOM



## International Journal for Research in Applied Science & Engineering Technology (IJRASET)




Figure.8 Three phase load voltage (RMS)




Figure.9 FFT analysis

### C. Case-3 Three Phase Fault Rectification Using D-STATCOM




Figure.10 Circuit diagram

## International Journal for Research in Applied Science & Engineering Technology (IJRASET)




Figure.11 Three phase load voltage (RMS)

PARAMETER	WITH d- STATCOM
VOLTAGE PEAK	340
VOLTAGE RMS	240
% THD	0.84

### V. CONCLUSION

This paper introduces an auxiliary control mechanism to enable the DVR to interrupt downstream fault currents in a radial distribution feeder. This control function is an addition to the voltage-sag compensation control of the DVR. The performance of the proposed controller, under different fault scenarios, including arcing fault conditions, is investigated based on time-domain simulation studies in the PSCAD/EMTDC environment. The study results conclude that the proposed multi loop control system provides a desirable transient response and steady-state performance and effectively damps the potential resonant oscillations caused by the DVR LC harmonic filter. The proposed control system detects and effectively interrupts the various downstream fault currents within two cycles (of 50 Hz). The proposed fault current interruption strategy limits the DVR dc-link voltage rise caused by active power absorption, to less than 15% and enables the DVR to restore the PCC voltage without interruption; in addition, it interrupts the downstream fault currents even under low dc-link voltage conditions. The proposed control system also performs satisfactorily under downstream arcing fault conditions.

### REFERENCES

- [1] Firouz Badrkhani Ajaei "Fault Current Interruption by the Dynamic Voltage Restorer "IEEE transactions on power delivery, vol. 28, no. 2, april 2013.
- [2] F. Badrkhani Ajaei, S. Afsharnia, A. Kahrobaeian, and S. Farhangi, "A fast and effective control scheme for the dynamic voltage restorer," IEEE Trans. Power Del., vol. 26, no. 4, pp. 2398–2406, Oct. 2011.
- [3] D. M. Vilathgamuwa, P. C. Loh, and Y. Li, "Protection of micro grids during utility voltage sags," IEEE Trans. Ind. Electron., vol. 53, no. 5, pp. 1427–1436, Oct. 2006.
- [4] S. S. Choi, T. X. Wang, and D. M. Vilathgamuwa, "A series compensator with fault current limiting function," IEEE Trans. Power Del., vol. 20, no. 3, pp. 2248–2256, Jul. 2005.
- [5] S. S. Choi, B. H. Li, and D. M. Vilathgamuwa, "Design and analysis of the inverter-side filter used in the dynamic voltage restorer," IEEE Trans. Power Del., vol. 17, no. 3, pp. 857–864, Jul. 2002.
- [6] J. G. Nielsen, F. Blaabjerg, and N. Mohan, "Control strategies for dynamic voltage restorer compensating voltage sags with phase jump," in Proc. IEEE APEC, 2001, pp. 1267–1273.
- [7] L. Gyugyi and E. C. Strycula, "Active AC power filter," in Proc. IEEE, IAS Annu. Meeting, 1976, pp. 529–529.
- [8] Power Electronics, B.C. Sen.



## International Journal for Research in Applied Science & Engineering Technology (IJRASET)

### BIOGRAPHY



Mr.M.Kamalakkannun was born on 1990 at Neyveli situated in Tamilnadu. He received his diploma in Electrical and Electronics Engineering from Aries Polytechnic College, Tamilnadu. He received his UG in Electrical and Electronics Engineering from PRIST University Pondicherry. He is currently perusing M.Tech Power Systems in PRIST University Pondicherry, Tamil Nadu. His areas of interests are Power quality issues, and electrical machines.



P.Arulkumar was born on 1991 at Neyveli situated in Tamilnadu, He received his diploma in Electrical and Electronics Engineering in 2010. He received his UG in Electrical and Electronics Engineering from IFET College of Engineering, Villupuram. Currently he is perusing M.Tech Power Systems in PRIST University Pondicherry, Tamil Nadu. His areas of interests are Power quality issues, and electrical machines.



Jasmine Susila. D was born in Tamilnadu in 1989. She received her UG degree in Electrical and Electronics Engineering from IFET College of Engineering, Tamilnadu. She received her PG degree in Electrical Drives and Control from Pondicherry Engineering College, Puducherry. Her research includes Power Quality, Power Electronic Converters and Renewable energy sources. She has presented papers in IEEE conferences and published many International Journal paper. She is currently working at PRIST University as an Assistant Professor.



10.22214/IJRASET



45.98



IMPACT FACTOR:  
7.129



IMPACT FACTOR:  
7.429



# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089  (24\*7 Support on Whatsapp)