



IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 10 Issue: III Month of publication: March 2022 DOI: https://doi.org/10.22214/ijraset.2022.40836

www.ijraset.com

Call: 🕥 08813907089 🔰 E-mail ID: ijraset@gmail.com



## Design, Fabrication and Performance of Twisted Tube Heat Exchanger

Komil Patel<sup>1</sup>, Priyeshnath Rathod<sup>2</sup>, Monark Patel<sup>3</sup>, Prit A. Patel<sup>4</sup>, Prit D Patel<sup>5</sup>

<sup>1, 2, 3, 4, 5</sup>Dept. of Chemical Engineering, Parul Institute of Technology (PIT), Parul University, Vadodara, India

Abstract: Heat exchangers are very much essential industrial as well as domestic equipment usedeveryday. The fundamental basis for this statistic is shell and tube technology is a cost effective, proven solution for a wide variety of heat transfer requirements. There are various limitations with technology which include inefficient usage of shell side pressure drop, dead or low flow zones around the baffles where fouling and corrosion can occur, and flow induced tube vibration, which can ultimately result in equipment failure.

This paper presents a recent innovation and development of a latest heat exchanger technology, known as Twisted Tube Technology, which has been able to overcome the limitations of conventional technology. This technology provides solution to almost all mentioned problems and provide good overall heat transfer coefficients through tube side enhancements. This paper primarily focuses on thermal analysis on twisted tube Heat exchangers.

Keywords: Heat exchangers, Twisted tube technology, conventional technology, thermal analysis

### I. INTRODUCTION

Heat Exchangers, one of the common equipment used for heating process fluids either by direct or indirect means. However the efficiency of the existing heat exchangers is poor and no longer high when used for longer time. In order to enhance the rate of heat transfer and efficiency twisted tube heat exchangers play a vital role. Heat exchangers are generally characterized by the compactness factor in m2/m3 (=/m) and it is generally accepted that values greater than 700/m characterize the compactness of the equipment. Although shell and tube heat exchangers can have a compactness factor, compact heat exchangers are often referred as non tubular devices.[1]

In order to augment heat transfer and to increase thermal performance of the heat exchangers heat transfer enhancement techniques are widely used. These techniques are classified in two groups, active and passive techniques. For active techniques heat transfer rate is improved by supplying extra energy to the system while in passive techniques the purpose is solved without use of any extra energy. The passive techniques include surface area extension (extended surfaces: fins), rough surfaces, inserts, turbulators also called swirl flow devices and coated surfaces.[2]

This paper describes an advance shell and tube heat exchanger with twisted tube which always enhances surface area provided due to twisting and corrugations. Recent advances in the range of design and operational reliability and flexibility have made twisted tube heat exchangers attractive in various industries, including offshore applications, pharma, dairy industries and in the field of petroleum processing industries. Taking into the size and surface area of contact, these heat exchangers can be cost effective in a wider range of applications than the traditional type of heat exchangers employed in process industries.

#### A. Twisted Tube Heat Exchanger

In twisted tube heat exchanger corrugated surface heat exchangers and extended surface heat exchangers have greater advantages when compared with conventional type of heaters. A twisted tube is a passive heat transfer enhancement device, generally classified in a swirl type flow device category. Swirl flow devices consist of a greater variety of geometrical flow arrangements in order to produce a stable form of forced vortex fluid motion in confined flows. This device facilitates fluid agitation and mixing of heat patterns induced by swirl flow.

The main advantages are mainly they do not require extra attention during assembly, maintenance, inspection and cleaning when intermediate viscous fluids are used.

This devices consists of helically twisted double radius oval tubes, welded their round ends to tube sheets. This device design is similar to structure of Human DNA which is double helical in patterns and extended all along the length and finally ends with DNA strands. The tubes contact one another at their wider sides, six times over the length of one twist pitch which makes the unit practically vibration free. The purely longitudinal shell side flow in twisted tube bundles thereby has an ability to provide high surface area (and density), low pressure drop, good heat transfer rates and coefficients.[3]



Volume 10 Issue III Mar 2022- Available at www.ijraset.com

### B. Enhancement Technique for Heat Transfer

Convective heat transfer is always achieved of expense of fluid flow and there by, pressure drop. But at the same time higher the pressure drop, the operating cast will be higher. Therefore it is important to minimize pressure drop for a given heat transfer coefficient. So that the overall cost of heat exchanger, which is sum of operating cast and fixed cast, is low.

The key to enhanced heat transfer is higher turbulence, which is not produced by increase in the fluid velocity but by improvement in basic pattern. Increased turbulent leads to not only enhanced heat transfer, but reduced fouling as well.

Heat transfer enhancement is one of the fastest growing areas of heat transfer technology. The technologies are classified into active and passive techniques depending on how the heat transfer performance is improved. A twisted tube is a typical passive method that uses a specific geometry to induce swirl on the tube side flow. The twisted tube heat exchanger has a bundle of uniquely formed tubes. Swirl flow in tube create turbulence to improve heat transfer, by helping the turbulent flow gives a high heat transfer rate.

#### II. METHODOLOGY OF TWISTED TUBE HEAT EXCHANGER

 $Q = F_t * U * A * \Delta T_{lm} (1)$  $D_h = d_{max} d_{min} / [3(d_{max} + d_{min})] (3d_{max} + d_{min})(d_{max} + 3d_{min})] 0.5(2)$ Nu=-hdh/k  $Re=\rho*\nu*dh/\mu$  $Pr = C_p * \mu / k$  $Fr = S^2 / d_{max} * d_h(3)$ Tube side coefficient :  $Nu = 0.21 * Re0.8Pr0.4*[1+3.74(s/d_{max} - 1] (Twt/Tbt)^{n}$ (4)Shell side co efficient :  $Nu = 0.521^* \text{ Re}^{0.8} * \text{Pr}^{0.4} * (\text{Twt/Tbs})^{-0.55}$ (5) Overall heat Transfer coefficient: U = (1/hi + L/kc + Rf + 1/ho)(6)Total Pressure drop  $\Delta P_{\text{Total}} = \Delta P_{\text{Entrance}} + \Delta P_{\text{Core}} + \Delta P_{\text{Exit}}(7)$ Tube side friction coefficient:  $f_D = 0.92 * (s / dh)^{-0.55} * Re^{-0.18}(8)$ Shell side friction coefficient : $f_D = 10.5 \text{ Fr}^{-1.6181 + 2.263 \text{log}Fr}$  (9) Core pressure drop  $\Delta P_{\text{Core}} = f_D * L / 2dh\rho v^2$ Nusselt number = f(Re, Pr, Fr)Darcy Friction Factor = f(Re, Fr)

#### III. RESULT

Twisted tube heat exchanger are compact and more efficient than conventional shell and tube heat exchangers the cost of fabrication and work during the fabrication is tedious work so it affect on the fabrication costing. This type of heat exchanger is more expensive than a conventional shell and tube heat exchanger but their payback time is quite short. Evaluating both twisted tube and shell and tube heat exchanger under the same operating conditions. The heat transformer coefficient is normally assumed as a basic measure of efficiency.

Component/	Shell	Twisted
Property	and	tube
	Tube	
No. of tubes	14	10
Tubeside heat	2721.5	2813.7
transfer		
coefficient		
Shell side	3514	5675.26
heat transfer		
coefficient		
Overall heat	892.31	1672.24
transfer		
coefficient		
	Property No. of tubes Tubeside heat transfer coefficient Shell side heat transfer coefficient Overall heat transfer	Propertyand TubeNo. of tubes14Tubeside heat transfer coefficient2721.5Shell side heat transfer coefficient3514Overall heat transfer892.31

$$Efficiency = \frac{1672.24 - 892.31}{1672.24} * 100$$

= 46.6%



International Journal for Research in Applied Science & Engineering Technology (IJRASET)

ISSN: 2321-9653; IC Value: 45.98; SJ Impact Factor: 7.538 Volume 10 Issue III Mar 2022- Available at www.ijraset.com

#### IV. CONCLUSION

From the above experimental study, it can be concluded that twisted tube heat exchange by greater advantages than conventional shell and tube heat exchanger. Twisted tube heat exchanger uses fewer tubes, less shell diameter and give more heat transfer for the same mass flow of fluid.

Nomenclature

 $d_h$ - hydraulic diameter. S –Twisted pitchin tube bundle,  $F_r$  - dimensionless swirl number 17.  $T_{ws}$ , Tbs = Temperature of wall and bulk flow on shell side.  $T_{wt}$ ,  $T_{bt}$  = Temperature of wall and bulk flow on tube side.  $F_d$ -Darcy friction factor.  $\Delta T_{lm}$ = logarithmic temperature difference.  $F_t$ = correction factor for log mean temperature difference.

#### REFERENCES

- [1] P.Eswar Raja Babu, "Heat transfer analysis on twisted tube heat exchanger technology", IJCET Volume 5, August 2015
- [2] Nitesh B. Dahare, "Review on Experimental Analysis and Performance Characteristic of Heat Transfer In Shell and Twisted Tube Heat Exchanger", International Journal of Engineering Research and General Science Volume 3, Issue 1, January-February, 2015.
- [3] Rakesh Prajapati, Saurabh Modi and Ronak Soni, "Experimental Analysis of Twisted Tube Heat Exchanger", IJCRT Volume 6, Issue 2, April 2018.
- [4] AFTAB AHMAD and ABDULLAH AL-QAHTANI, "Experimental Study of Fouling Resistance in Twisted Tube Heat Exchanger", Norwegian University of science and technology Department of energy, Volume 6, Issue 2, April 2018.
- [5] R. Donald Morgan, "Twisted Tube Heat Exchanger Technology", Brown Fintube company 2015.
- [6] Bhushan S. Waghchar, "Experimental analysis of heat transfer in shell and twisted tube heat exchanger", IJCET Volume 4, August 2016.
- [7] Vivek P. Thawkar, "Experimental and CFD Analysis of Twisted Tube Heat Exchanger under Forced Convection", IJSR 2013.
- [8] Pradip Pathade, Anmol Singh, "Twisted Type Shell and Tube Heat Exchangers", IJEDR Volume 5, Issue 2, 2017.
- [9] Christian Berner, "Twisted tube heat exchanger", KOCH Heat Transfer Company.
- [10] Nimish Dubey, Mr. Morrish Kumar," Design modification in heat exchanger twisted tape for heat transfer enhancement", IJESRT Jujly 2017.
- [11] Shambhu Kumar Mahato\*, Subhas Chandra Rana, Rabindra Nath Barman, Sohom Goswami," Numerical Analysis of Heat Transfer and Fluid Flow through Twisted Hexagonal and Square Duct and their Comparisons", CEt Vol 71, 2018.
- [12] Kushal Desai, Priyeshnath Rathod, Pallav Bariya, Rohan Doshi and Abhishek Bagu," Experimental analysis and investigation on twisted tube shell type heat Exchange Research Journal of Engineering Sciences", Vol. 10(3), 36-38, September (2021).
- [13] Sven Olaf Danielsen, "Investigation of a twisted-tube type shell-and-tube heat exchanger", NTNU, June 2009.
- [14] Ms.Vandita,Thantharate,Dr.D.B.Zodpe, "Experimental and Numerical Comparison of Heat Transfer Performance of Twisted Tube and Plain Tube Heat Exchangers", IJSER Volume 4, Issue 7, July-2013.
- [15] Nitesh B. Dahare, Dr. M. Basavaraj, "Experimental Analysis and Performance Characteristic Of Heat Transfer In Shell and Twisted Tube Heat Exchanger", IRJET Vol.02 Issue 07, Oct 2015.
- [16] Alok Shukla, Prakash Kumar, Dr. Deo. Raj Tiwari, "Design Procedure of Shell and Tube Heat Exchanger", IJETR, Volume-3, Issue-12, December 2015.
- [17] Uttam h. Patel, Kedar n. Bhojak, "An Overview of Shell & Tube Type Heat Exchanger Design by Kern's Method", IJIERE, Volume 2, Issue , 2015.
- [18] Butterworth.d ,"Development in Shell and Tube Heat Exchanger", ICHMT Int. Symp. On New Development in Heat Exchanger, 6-9Sep, 1993.
- [19] Kotcherla Sriharsha, Venkata Ramesh Mamilla, "Strength Analysis of Tube to Tube Sheet Joint in Shell and Tube Heat Exchanger", IJSETR Volume 1, Issue 4, October 2012.
- [20] Paresh Patel, Amitesh paul, "Thermal Analysis Of Tubular Heat Exchanger By Using Ansys", IJERT, Vol. 1, Issue 8, October -2012
- [21] Kotcherla Sriharsha, Venkata Ramesh Mamilla, "Strength Analysis of Tube to Tube Sheet Joint in Shell and Tube Heat Exchanger", IJSETR Volume 1, Issue 4, October 2012.
- [22] Haran, Ravindra Reddy, "Thermal Analysis of Shell and Tube Heat Ex-Changer Using C and Ansys", (IJCTT) volume 4 Issue 7– July 2013.
- [23] Effectively Design Shell-and-Tube Heat Exchangers, CHEMICAL ENGINEERING PROGRESS FEBRUARY 1998
- [24] Vikil D. Malwe M. B. Mawale, "Thermal Analysis of Heat Transferring Components in the Power Plant A Review, (IJERT) Vol. 2 Issue 1, January- 2013 ISSN: 2278-0181.
- [25] TEMA, 1988 Standards of the Tubular Exchanger Manufacturers" Association, New York 7th ed.
- [26] Butterworth, D., Guy, A. R., and Welkey, J. J., Design and Application of Twisted Tube Heat Exchangers.
- [27] Small, W. M., and Young, R. K. 1979 Heat Transfer Engineering, Vol.1.
- [28] Gentry, C. C., Chem. Engng. Progress, Vol. 86, No. 7 pp 48-57.
- [29] Kral, D, and Lutcha, J, 1992, "New Developments in Tubular Heat Exchangers- the Helixchanger", Paper presented at UK Heat Transfer Soc. Forum, London, 21 May.
- [30] Blackwelder, R. and Kreith, F. 1970. "Experimental investigation of heat transfer and pressure drop in a decaying swirl flow", Transaction ASME, Augmentation of Convective Heat and Mass Transfer.
- [31] Blazo Ljubicic. "Twisted Tube Heat Exchangers: Technology and Application", Brown Fintube Company 12602 FM 529 Road Houston, Texas 77240-0082 USA.
- [32] The Heat Transfer by K.A Gavahane, Unit operation -2, Nirali publications, ISBN.978-81-96396-12-1.
- [33] Prof. Naresh B. Dhamane et al. Heat Transfer Analysis Of Helical Strip Insert With Regularly Spaced Cut Sections Placed Inside Circular PipelInternational Journal of Modern Engineering Research (IJMER) Vol. 2, Issue. 5, Sep.-Oct. 2012 pp-3711-3716.
- [34] JSiminwang, Jianwen, (2009), An Experimental investigation of heat Transfer enhancement for a shell and tube heat exchanger, Applied Thermal Engineering, Vol.29. pp.2433-2438.
- [35] A. E. Bergles and Raj M. Manglik. "Heat Transfer and Pressure Drop Correlations for Twisted-Tape Inserts in Isothermal Tubes: Part I Laminar Flows". In: Journal of HeatTransfer (Transactions of the ASME) 115.November 1993 (1993), pp. 881–889.











45.98



IMPACT FACTOR: 7.129







# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 🕓 (24\*7 Support on Whatsapp)