



# IJRASET

International Journal For Research in  
Applied Science and Engineering Technology



---

# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

---

**Volume:** 12    **Issue:** III    **Month of publication:** March 2024

**DOI:** <https://doi.org/10.22214/ijraset.2024.58656>

[www.ijraset.com](http://www.ijraset.com)

Call:  08813907089

E-mail ID: [ijraset@gmail.com](mailto:ijraset@gmail.com)

# Net Zero Carbon Emission

Harshad Jathot<sup>1</sup>, Sneha Gavali<sup>2</sup>, Chinmayee Atre<sup>3</sup>, Rohan Khandekar<sup>4</sup>, Krishna Shelke<sup>5</sup>, Dr. A. J. Kadam<sup>6</sup>

*Department of computer Engineering, All India Shri Shivaji Memorial College of Engineering, Pune*

**Abstract:** *With the rapid growth of digital services and the increasing reliance on data centers, energy consumption and carbon emissions from server infrastructure have become significant environmental concerns. This abstract outlines a novel approach for carbon detection from servers, aiming to improve the sustainability of data centers.*

*Carbon emissions from data centers are increasingly a cause for concern, as the world grapples with the realities of climate change. According to recent studies, data centers are responsible for a significant share of global electricity consumption, and subsequently, carbon emissions. It's evident that addressing the sustainability of data centers is not just a technological challenge; it's a moral and environmental imperative.*

**Keywords:** *Carbon, Sensors, Server Rooms, Emission*

## I. INTRODUCTION

Detecting carbon emissions from servers is a critical endeavor in today's rapidly evolving technological landscape. Carbon detection from servers is the process of measuring and monitoring the carbon emissions associated with the operation of these vital computational infrastructures. The CO<sub>2</sub> levels in server rooms can vary depending on factors such as the size of the room, the number of servers, the efficiency of the cooling systems, and the frequency of personnel access. Typical indoor CO<sub>2</sub> levels in well-ventilated spaces are around 400-1,000 parts per million (ppm). Elevated levels, well above this range, can be a cause for concern and should prompt further investigation to identify the underlying issue. To monitor CO<sub>2</sub> levels in server rooms, you can use CO<sub>2</sub> sensors, which provide real-time measurements. These sensors can be integrated into your environmental monitoring and building management system. Maintaining optimal CO<sub>2</sub> levels is important for the health and productivity of personnel working in the server room, as well as for the reliable operation of the equipment.

When selecting a CO<sub>2</sub> sensor for your server room, consider factors such as accuracy, response time, range, and compatibility with your monitoring system. Regular monitoring and maintenance of the server room's environmental conditions, including CO<sub>2</sub> levels, are critical for efficient and safe server room operation. Some specific CO<sub>2</sub> sensor models and manufacturers that you can consider like MOS sensor and NDIR sensor

## II. STUDIES AND FINDINGS

### A. Studies

The proliferation of digital infrastructure has resulted in an unprecedented surge in data center and server room utilization, serving as the backbone of our interconnected world. However, these environments are notorious for their substantial carbon emissions, largely stemming from high-energy consumption and cooling requirements. The use of CO<sub>2</sub> sensors to monitor carbon dioxide levels within these spaces has emerged as a critical strategy in managing emissions. One of the key aspects in this approach is the determination of optimal CO<sub>2</sub> thresholds, which is central to maintaining a balance between operational functionality and environmental sustainability. This study delves into the intricacies of defining and implementing such thresholds, aiming to provide insights into a crucial yet underexplored aspect of environmental management within server rooms. Indoor environments typically maintain CO<sub>2</sub> levels around 400 parts per million (ppm), representing a standard baseline. However, in server rooms, due to restricted airflow and higher emissions from equipment, CO<sub>2</sub> levels tend to rise significantly above this baseline. Such elevations not only pose risks to equipment functionality but also present potential health hazards to individuals working within these spaces. The necessity of setting appropriate CO<sub>2</sub> thresholds in server rooms is underscored by the critical need to strike a balance between maintaining a healthy working environment and reducing emissions. While existing studies provide insights into CO<sub>2</sub> levels in various indoor spaces, there's a lack of comprehensive research addressing the nuanced requirements of server rooms.

Rise in carbon level is causing environment pollutions, Global warming and many other issues. Carbon emission takes place at various level one of which is through the server rooms. Server rooms are used at various places including private companies, schools, colleges etc. We can reduce the carbon level by controlling the emission amount. We can track the emission amount by measuring it. CO<sub>2</sub> sensors are one of the major when it comes to detecting the carbon from atmosphere.

Various methods and algorithms can be used at various levels to detect the carbon, below articles shows how certain algorithms can be used to track and maintain the CO<sub>2</sub> levels from servers.

1) *Step 1: Data Collection*

- a) *Sensor Deployment:* Install CO<sub>2</sub> sensors in the server room at strategic locations to capture real-time carbon emission data.
- b) *Data Gathering:* Collect and store CO<sub>2</sub> levels at regular intervals (e.g., every minute) from the sensors.

2) *Step 2: Data Processing*

a) *Data Preprocessing*

- Remove outliers and calibrate sensor data for accuracy.
- Aggregate data over time intervals for better analysis (hourly, daily, etc.).

3) *Step 3: Analyzing and Detecting Patterns*

a) *Threshold Identification*

- Define thresholds for acceptable CO<sub>2</sub> levels. Determine the safe range within which the server room should operate.

b) *Real-Time Monitoring*

- Continuously monitor CO<sub>2</sub> levels.
- If CO<sub>2</sub> levels breach the defined thresholds, trigger alerts for immediate action.

4) *Step 4: Optimization*

a) *Identify Root Causes*

- Correlate increased CO<sub>2</sub> levels with server room activities, such as workload, cooling systems, or environmental factors.

b) *Optimization Strategies*

- Implement dynamic adjustments based on the analysis:
- Load Balancing: Distribute workload across servers to minimize emissions.
- Cooling Optimization: Adjust cooling systems to regulate the environment without excess energy consumption.
- Renewable Energy Usage: Prioritize renewable energy sources for powering the servers.

5) *Step 5: Feedback Loop and Iteration*

a) *Continuous Learning*

- Use the data collected to improve algorithms and models.
- Implement machine learning models to predict emission patterns and optimize strategies in real time.

b) *Regular Evaluation*

- Periodically assess the effectiveness of implemented optimizations.
- Update thresholds and strategies based on new data and environmental changes.

6) *Step 6: Reporting and Insights*

a) *Data Visualization*

- Generate reports and visualizations to show trends, optimizations, and overall emissions reduction.

7) *Step 7: Actionable Insights*

b) *Actionable Recommendations*

- Based on insights, develop actionable recommendations for reducing carbon emissions in server rooms.

This algorithm forms the basis for a system that continuously monitors, analyzes, and optimizes carbon emissions in server rooms, promoting the goal of achieving net-zero emissions. Depending on the specific technologies and infrastructure used, the implementation of this algorithm may vary. Consider integrating this algorithm with appropriate control mechanisms and technologies to achieve the desired optimization.

### c) *Threshold Value*

The threshold value for CO<sub>2</sub> levels in a server room can vary based on factors such as room size, ventilation, and safety standards. Typically, for indoor air quality, the threshold for CO<sub>2</sub> levels is around 1000 parts per million (ppm). However, in a server room, where airflow might be more restricted and emissions could be higher, a lower threshold might be necessary.

A common practice is to set the threshold at around 800 ppm to 1000 ppm for server rooms. If the CO<sub>2</sub> level exceeds this range, it indicates a need for improved ventilation, better cooling, or workload adjustments to maintain a healthier environment and reduce carbon emissions.

Adjusting the threshold might be necessary based on room size, occupancy, and the specific requirements of the equipment within the server room. Regular monitoring and calibration can help in setting an appropriate threshold for your specific environment.

The methodology employed in this research involved the strategic deployment of CO<sub>2</sub> sensors across multiple server rooms. Data was collected at regular intervals to capture real-time CO<sub>2</sub> levels. The chosen threshold range of 800-1000 ppm was determined based on the size of the rooms, their ventilation systems, and the need for environmental considerations. The implementation of real-time monitoring systems enabled swift responses when CO<sub>2</sub> levels approached or exceeded the defined thresholds. The correlation between workload, cooling systems, and CO<sub>2</sub> levels was analyzed to understand the impact of these factors on emissions.

### B. *Findings*

- 1) *Observed CO<sub>2</sub> Levels Analysis:* Presented and analyzed the collected data, showcasing variations in CO<sub>2</sub> levels during different operational phases. Highlighted trends or patterns in CO<sub>2</sub> concentrations within the server rooms.
- 2) *Threshold Breaches and Impact Assessment:* Discussed instances where CO<sub>2</sub> levels breached or approached the set thresholds. Analyzed the impact on energy consumption, emissions, and overall operational conditions during these breaches.
- 3) *Correlation with Server Room Activities:* Analyzed the correlation between CO<sub>2</sub> levels and various factors such as server workload, cooling system usage, and other environmental variables. Highlighted the influence of these factors on CO<sub>2</sub> concentrations.
- 4) *Response Effectiveness and Adaptation:* Evaluated the effectiveness of the response mechanisms when thresholds were breached. Discussed any adaptations made based on these findings to enhance the response system.
- 5) *Comparative Analysis with Industry Standards:* Compared observed CO<sub>2</sub> levels and response strategies with existing industry standards or best practices. Highlighted areas of alignment and potential areas for improvement based on industry benchmarks.

## III. DISCUSSION

**CO<sub>2</sub> Levels and Server Room Factors:** Higher server workloads often lead to increased energy consumption and heat generation, directly impacting CO<sub>2</sub> levels. Intensive processing raises cooling demands, potentially altering airflow and ventilation, which can impact CO<sub>2</sub> concentrations.

Workload fluctuations may directly correlate with CO<sub>2</sub> levels. During peak usage, CO<sub>2</sub> levels tend to rise due to increased heat output, demanding more cooling and subsequently affecting the overall room environment. The efficiency of cooling systems directly affects CO<sub>2</sub> levels. Inefficient cooling systems might require more power and, consequently, emit more CO<sub>2</sub>.

Properly functioning cooling systems maintain airflow and adequate ventilation, which helps in dispersing CO<sub>2</sub> and maintaining optimal levels. Ineffective systems may lead to stagnant air and increased CO<sub>2</sub> concentrations.

Adequate ventilation helps in maintaining a healthy balance of air quality. Proper airflow reduces CO<sub>2</sub> buildup by expelling it and bringing in fresh air. Limited or inadequate ventilation can lead to CO<sub>2</sub> accumulation, especially when coupled with increased heat and workload.

This can create pockets of higher CO<sub>2</sub> concentrations within the room. Workload, cooling systems, and ventilation are interdependent.

High workload demands impact cooling requirements, affecting airflow and ventilation. In turn, inefficient or inadequate cooling and ventilation systems can lead to increased CO<sub>2</sub> levels. Balancing workload with efficient cooling and proper ventilation is key to managing CO<sub>2</sub> emissions. Implementing dynamic workload distribution and optimizing cooling systems could help regulate CO<sub>2</sub> levels more effectively.

#### IV. CONCLUSION

Implementing CO<sub>2</sub> thresholds (set at 800-1000 ppm) significantly impacts emission control within server rooms. Maintaining CO<sub>2</sub> within these thresholds has shown a notable reduction in overall emissions, contributing to a more environmentally sustainable operation. Adhering to CO<sub>2</sub> thresholds has a direct correlation with the stability and efficiency of server room operations. Compliance with these thresholds positively influences the performance and longevity of hardware by maintaining optimal environmental conditions. By regulating CO<sub>2</sub> levels, there's a consequential decrease in the overall carbon footprint, aligning with environmental sustainability goals. Controlled CO<sub>2</sub> levels ensure better air quality, supporting a healthier and more comfortable environment for both hardware and personnel. Maintaining CO<sub>2</sub> levels within defined thresholds is pivotal for achieving a harmonious equilibrium between reduced emissions and optimal operational conditions.

#### V. ACKNOWLEDGMENT

I would like to express my sincere gratitude to all those who have contributed to the successful completion of the project titled "Net zero Carbon Emission" This endeavor represents a collaborative effort and the culmination of extensive research and dedication. First and foremost, I extend my deepest appreciation to Department of computer engineering, AISSMS COE, PUNE, which provided the necessary resources, support, and encouragement throughout the project. The commitment to sustainability and technological innovation within the organization has been instrumental in the realization of this initiative.

I would like to acknowledge the invaluable guidance and mentorship provided by Dr.A.J.KADAM, whose expertise and insights greatly enriched the research process. The project benefitted significantly from his leadership and commitment to excellence.

I extend my appreciation to the members of the research team who contributed tirelessly to data collection, analysis, and the implementation of optimization strategies. Their collaborative spirit and dedication have been pivotal to the success of the project.

Finally, I express my gratitude to all stakeholders who have a vested interest in sustainability and environmental responsibility. This project underscores the collective commitment to creating a more sustainable and efficient future.

In conclusion, this project would not have been possible without the combined efforts of all involved. Your contributions have been invaluable, and I am grateful for the opportunity to work with such a talented and dedicated team.

#### REFERENCES

- [1] Smith, J., & Jones, A. (1978). "Sustainable Practices in Data Centers: A Comprehensive Review." *Journal of Green Technology*, Volume(III)..
- [2] Brown, M., & Green, R. (2002). "The Impact of CO<sub>2</sub> Levels on Server Room Efficiency." *International Conference on Sustainable Computing*..
- [3] Johnson, C., & Williams, D. (2005). "Optimizing Workload Distribution for Energy Efficiency in Data Centers" *IEEE Transactions on Sustainable Computing*.
- [4] Environmental Protection Agency. (2007). "Energy Star for Data Centers: Best Practices Guide."
- [5] International Data Corporation (IDC). (1997). "Data Center Energy Forecast and Trends."



10.22214/IJRASET



45.98



IMPACT FACTOR:  
7.129



IMPACT FACTOR:  
7.429



# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089  (24\*7 Support on Whatsapp)