



# IJRASET

International Journal For Research in  
Applied Science and Engineering Technology



---

# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

---

**Volume: 6      Issue: 1      Month of publication: January 2018**

**DOI: <http://doi.org/10.22214/ijraset.2018.1438>**

**[www.ijraset.com](http://www.ijraset.com)**

**Call:  08813907089**

**E-mail ID: [ijraset@gmail.com](mailto:ijraset@gmail.com)**

# Study of Improvement in the Performance of Triple Effect Vapor Absorption System Using Loop Heat Pipes

Ankit Dwivedi<sup>1</sup>, R S Mishra<sup>2</sup>

<sup>1,2</sup>Dept. of Mechanical Engineering, Delhi Technological University, Delhi

**Abstract:** The triple effect vapor absorption refrigeration system (VARs) works at higher temperatures (>150-160°C). This high temperature working of the cycle helps in achieving higher COP<sub>I</sub> and COP<sub>II</sub>. This research analysis works on reducing the heat input in the generators by use of two Loop Heat Pipes (LHPs) installed in the high and medium temperature levels. The simulations have found that the improved COP<sub>I</sub> & COP<sub>II</sub> are 2.545 and 0.588 respectively. Also the percentage increase in performances of the modified system has been recorded as 61.112 % and 25.146% respectively. Simulations also found that the average T<sub>C</sub> can be maintained at 151.18 °C. The increase in the performance characteristics shows a positive gradient with the increase in the temperature of operation of LHP. The average Q<sub>Leak</sub> and Q<sub>Cond</sub> are found to be 89.44 kW and 71.68 kW respectively.

## I. INTRODUCTION

Loop Heat Pipe (LHP) is an evaporator-condenser that works on the thermo-siphon effect. It operates and transfers heat without any requirement of input work. It acts as a super-conductor owing to the high heat transfer rates related to the evaporation and condensation. The heat pipe is a wicked structure, outside of which the heat is absorbed by the working fluid of the LHP from the ambient and the fluid gets vaporized. This vapor passes through the porous wicked structure and moved towards the condenser of the LHP through the Vapor Line. The vapor rejects heat in the condenser and gets condensed. These condensates then move towards the Compensation Chamber (CC) connected to the evaporator of the LHP and gets accumulated there.




Fig 1: Cyclic process of a Loop Heat Pipe<sup>[35]</sup>

There is some leakage of heat of associated with the LHP from CC, Liquid and Vapour Lines, From the wick etc. These losses are although negligible but can be reduced up to an extent by the proper selection of materials and designs.




Fig 2: Schematic of LHP [36].

A triple effect vapor absorption system refrigeration system (VARS) is used when the source temperature is high (>140-150 °C). The high temperature also corrodes the material of the generator and connecting lines. The parallel flow type heat exchanger is shown and explained in fig 3. This VARS system is very useful in utilizing a waste heat. The efficiency of the triple effect system is also relatively higher as the operating temperature is very high comparatively.

## II. LITERATURE REVIEW

Fabian Korn et al. [2012] performed several vital experiments on heat pipes to establish it to be one of the most effective procedures to transport thermal energy from one point to another, mostly used for cooling [6]. Sameer Khandekare et al. [2010] performed experiments on the global thermal performance modeling of Pulsating Heat Pipes (PHPs) requires local, spatio-temporally coupled, flow and heat transfer information during the characteristic, self-sustained thermally driven oscillating Taylor bubble flow, under different operating conditions [7]. Jozef Hužvář, Patrik Nemec et al. [2007] used heat pipe, observed its basic principles and operating limits. High temperature heat pipes were evaluated for use in energy conversion applications such as fuel cells, gas turbine re-combustors, and Stirling cycle heat sources, with the resurgence of space nuclear power, additional applications include reactor heat removal elements and radiator elements [8]. R.Z. Wanget al. [2008] added heat pipes in adsorption water chiller or ice maker initials. His work showed that the adsorption refrigerators are very efficient [10]. Pracha Yeunyoungkul et al. [2009] aimed at experimentally investigating the application of a closed loop oscillating heat pipe (CLOHP) as the condenser for a vapor compression refrigeration system [14]. R. Rajashree et al. [1990] went through a numerical analysis of an unsteady, viscous, laminar, incompressible, two dimensional heat and mass transfer, in the vapour gas region of gas loaded circular heat pipe [20]. Da-Wen Sun (1996) performed a detailed thermodynamic analysis of the properties of these binary fluids and expressed in polynomial equations. The performances of three cycles were compared. M.M. Talbi et al. (2000) carried out an exergy analysis on a single-effect absorption refrigeration cycle with lithium-bromide±water as the working fluid pair. E. Kurem et al. (2001) analyzed the Absorption Heat Pump (AHP) and Absorption Heat Transformers (AHT) using ammonia-water and water-lithium bromide solutions. A fundamental AHP and AHT systems was described and explained the operating sequence. R.D. Misra et al. (2002) applied the therm-o-economic theory to the economic optimization of a single effect water/LiBr vapour absorption refrigeration system for air-conditioning application. S.A. Adewusi et al (2004). studied the performance of single-stage and two-stage ammonia–water absorption refrigeration systems (ARSs). They calculated entropy generation of each component and the total entropy generation of all the system components as well as COP of the ARSs. S. Arivazhagan et al. (2006) investigated experimentally on the performance of a two-stage half effect vapour absorption cooling system. The prototype is designed for 1 kW cooling capacity using HFC based working fluids (R134a as refrigerant and DMAC as absorbent). Rabah Gomri et al. (2008) performed exergy analysis of double effect lithium bromide/water absorption refrigeration system. The system consisted of a second effect generator between the generator and condenser of the single effect absorption refrigeration system, including two solution heat exchangers between the absorber and the two generators. S.C. Kaushik et al. (2009) presented the energy and exergy analysis of single effect and series flow double effect water–lithium bromide absorption systems. They developed a computational model for the parametric investigation of the systems. Berhane H. Gebreslassie et al. (2010) performed an exergy analysis, which only considered the unavoidable exergy destruction, conducted for single, double, triple and half effect Water–Lithium bromide absorption cycles. Gulshan Sachdeva et al. (2014) performed an exergy analysis of VAR system using LiBr-H<sub>2</sub>O as working fluid with the modified Gouy-Stodola approach. Karl Ochsner et al. (2008) developed a new CO<sub>2</sub>-heat pipe with high-grade steel corrugated pipe system, which – contrary to other



pipe systems permits raw length up to 100 m. They also described the establishment of the heat pump system in general. Ankit Dwivedi et al. (2018) through computer simulations of the replacement of condensers from single, double and half effect VARS, showed the improvements in the performance in COP<sub>I</sub> and COP<sub>II</sub>. Waste heat is being utilized in the cycle from some outside source, while the cycle itself rejects heat at the saturation temperature of the refrigerant which in case is as high as the generator. This heat is taken away by the working fluid of the condenser (Air, Water etc). It can be taken away by the mixture of refrigerant from the absorber as well which already works at the condenser temperature. The LHP can be used for this purpose. It can replace the condenser and help in the intra cycle heat exchange. The two condensers working at higher temperatures (>100°C) can be replaced in the triple effect cycle by LHPs. The bulky condensers will be removed and flexible heat pipes will take its place. Also as mentioned earlier the LHPs will act as a superconductor with having higher capacity and higher heat transfer coefficient. Some of the research works have showed the options for more analysis in these aspects.

### III. SYSTEMS DESCRIPTION

It can be explained by the fig 3 what are the basic components and cycle processes of the triple effect VARS. This is a parallel flow triple effect system which has 3 condensers (Low(LC), Medium(MC) and High(HC)), 3 generators (Low(LG), Medium(MG) and High(HG)), an absorber, an evaporator, 3 Heat Exchangers (Low H.E x, MedH. Ex, HighH. Ex), pumping devices and throttle valves. The mixture is pumped to the high temperature generator HG (>working at 150°C) through the 3 heat exchangers. A major part of the rich refrigerant then gets separated from the mixture and is transferred through HC to the evaporator to produce the refrigeration. The remaining mixture from the HG then is throttled to the MG(>120°C) where it is heated and the separated strong refrigerant is transferred to the evaporator through MC and throttle valves. The remaining mixture from MG is then throttled to the LG(>80-90°C) where the above process takes place. Finally the remaining mixture is throttled to the absorber. This 3 stage process helps the separation strong refrigerant well administered.




Fig 3: A Triple Effect (Parallel) Vapour Absorption System

The proposed modifications can be well described in fig 4. Here HC, LC, Low H.Ex and Med H.Ex are to be removed from LHPs. Understanding that the temperature is sufficiently high at this level (i.e. 120°C -150°C), LHPs will perform the tasks of condensers and H.Ex reduces the size and complexity of the Heat Exchangers. The cost associated can also be reduced. The design of the LHP

will be very simple when compared with that of H. Ex. Heat is removed at the evaporator size on the LHP from the condensing strong refrigerant. This heat will be transferred to the mixture coming from the absorber. The effectiveness on the the LHP will be higher than the other heat exchangers owing to the high heat transfer coefficients. The simulations are executed and the results are as follows. The table 1 consists of the terminology used in the analysis.




Fig.4: Modified Triple Effect Vapour Absorption System

Table 1: Terms Used in Simulation

Terms	Abbreviations
Refrigeration Effect in kW	RE (kW)
Heat rejected in absorber in kW	$Q_a$ (kW)
Heat supplied in generator in kW	$Q_g$ (kW)
Heat rejected in condenser of LHP in kW	$Q_{cond}$ (kW)
Heat absorbed in evaporator of LHP in kW	$Q_{eva}$ (kW)
Absorber Temperature in °C	$T_{La}, T_{Ha}$ (°C)
Generator Temperature in °C	$T_{Hg}, T_{LG}, T_{MG}$ (°C)
LHP Condenser Temperature in °C	$T_c$ (°C)
Evaporator Temperature in °C	$T_E, T_e$ (°C)
Heat Rejected in Condenser in kW	$Q_C$ (kW)
First Law Coefficient of Performance	$COP_I$
Second Law Coefficient of Performance	$COP_{II}$
Heat Leaked from the LHP in kW	$Q_{Leak}$ (kW)
Percentage Improvement in First Law Coefficient of Performance	$\%COP_{I imp}$
Percentage Improvement in Second Law Coefficient of Performance	$\%COP_{II imp}$
Improvement in First Law Coefficient of	$COP_{I imp}$

Performance	
Improvement in Second Law Coefficient of Performance	$COP_{II\ imp}$
Low Temperature Generator, Condenser	LG, LC
Medium Temperature Generator, Condenser	MG, MC
High Temperature Generator, Condenser	HG, HC

#### IV. RESULTS AND DISCUSSIONS

From Fig 5 to Fig 8 shows the various variations in  $COP_I$  &  $COP_{II}$ . Fig 5 describes the comparison of  $COP_I$  improvement in the modified system and the  $COP_I$  in the basic triple effect cycle. The average  $COP_I$  of modified system can be observed to be 2.545.




Fig 5: Comparison between  $COP_I$  and  $COP_{I\ imp}$  plotted with  $Q_{Cond}$

It can be seen in the fig 6 how  $COP_{II}$  of the proposed modified system stands against the original system. There's a continuous increase in the  $COP_{II}$ , as the slope in the beginning is positive and in the later stage the increase in  $Q_{Cond}$  may not yield in higher rises in  $COP_{II}$ . The average  $COP_{II}$  of modified system can be 0.588.




Fig 6: Comparison between  $COP_{II}$  and  $COP_{II\ imp}$  plotted with  $Q_{Cond}$

Fig 7 shows the increase in COP<sub>I</sub> & COP<sub>II</sub> relatively over the range of Q<sub>Cond</sub>. It can be seen that COP<sub>I</sub> has a higher and direct effect of Q<sub>Cond</sub> as its being used in improving it directly. The COP<sub>II</sub> on the other hand doesn't show a sharp rise as COP<sub>I</sub> does. The reduction of heat wastage in the system no doubt helps in decreasing the exergy loss. Both external and internal irreversibility are reduced.




Fig 7: COP<sub>I</sub> and COP<sub>II</sub> plotted with Q<sub>Cond</sub>

Fig 8 in a way is developed to show the percentage rise in the COP<sub>I</sub> and COP<sub>II</sub> owing to the use of LHPs. As discussed earlier the COP<sub>I</sub> is directly affected by the Q<sub>Cond</sub>. Here the average percentage rise in COP<sub>I</sub> is found to be around 61.112 % and the average rise in COP<sub>II</sub> is 25.146%. Also if the designs can be changed so that LHPs are able utilize more heat and the leaks are reduced the COP<sub>I</sub> can be further improved.




Fig8: Variation of %COP<sub>I imp</sub> and % COP<sub>II imp</sub> plotted with Q<sub>Cond</sub>

The Fig 9 & Fig 10 shows the percentage improvements in the performance with the range of LHP condenser temperature  $T_C$  and HG temperature  $T_G$ . With the ranging  $T_C$  rise in  $COP_I$  has a positive slope as discussed earlier and as the  $T_C$  increase further the availability also increases. Increase in the availability helps in increasing  $COP_I$  as the heat to be utilized increases.  $COP_{II}$  also follows, and increase in the  $COP_{II}$  is recorded by the simulations.




Fig9: Comparison of %age improvements in  $COP_I$  &  $COP_{II}$  varying the  $T_C$

Fig 10 describes the variations of performance with the range of  $T_G$ . With rise in  $T_G$  the  $COP_I$  has a sharp increase, whereas the  $COP_{II}$  has a gradual increase.




Fig 10: Comparison of %age improvements in  $COP_I$  &  $COP_{II}$  varying the  $T_G$

The Fig 11 & Fig 12 show the improved performance with the temperature range.






Fig 11: Comparison of COP<sub>I</sub> & COP<sub>II</sub> varying the T<sub>c</sub>




Fig 12: Comparison of COP<sub>I</sub> & COP<sub>II</sub> varying the T<sub>g</sub>

Fig 13 and Fig 14 describe the variations in Heat Leaked and Heat Utilized in the LHPs along the temperature. In the figure as the temperature of the LHP condenser increases it can be observed that heat utilized in condenser increases. The average heat utilized in the LHP condenser is 71.68 kW.




Fig 13: Comparison of  $Q_{Leak}$  &  $Q_{Cond}$  varying the  $T_c$

On the other hand, the figure below shows the same variation with temperature of HG. The heat leak  $Q_{Leak}$  is decreasing with the increase in  $T_G$ . The average heat that has leaked the LHP is 89.44 kW over the ranges of temperatures.




Fig 14: Comparison of  $Q_{Leak}$  &  $Q_{Cond}$  varying the  $T_g$

Fig 15 shows the dependency of TC on TG. As the TG increases TC also increases. Direct dependence can be observed from the figure below. The average temperature can be managed to be achieved in the condenser of LHP is 151.18 °C.




Fig 15: Variation of  $T_c$  with the  $T_g$

The Figure 16 to 19 the performance of the modified system can be studied with the variations in the working temperatures.




Fig 16: Variation of improvement in  $COP_{II}$  with the  $T_c$




Fig 17: Variation of improvement in  $COP_{II}$  with the  $T_g$




Fig 18: Variation of improvement in COP<sub>I</sub> with the T<sub>G</sub>




Fig 19: Variation of improvement in COP<sub>I</sub> with the T<sub>C</sub>

### V. CONCLUSIONS

Following the results of the simulations, following conclusions can be made

- A. The average improved COP<sub>I</sub> & COP<sub>II</sub> are 2.545 and 0.588 respectively.
- B. The percentage increase in COP<sub>I</sub> & COP<sub>II</sub> can be observed to be 61.112 % and 25.146% respectively.
- C. The COP<sub>I</sub> has a sharper rise over the range when compared to the COP<sub>II</sub> for the range of Q<sub>Cond</sub>.
- D. The COP<sub>I</sub> shows an increasing slope for the entire range while the COP<sub>II</sub> shows a decreasing slope for the entire range of the T<sub>G</sub> and T<sub>C</sub>.
- E. Increase in the temperature T<sub>G</sub> provides the desirable results such as reduction in the Q<sub>Leak</sub> and increase in Q<sub>Cond</sub> and average T<sub>C</sub> is found to be 151.18 °C.
- F. Average Q<sub>Leak</sub> and Q<sub>Cond</sub> are found to be 89.44 kW and 71.68 kW respectively.

**REFERENCES**

- [1] Saeed, Sedigh , Hamid. Saffari ,”Thermodynamic analysis of single effect and half effect absorption refrigeration system” International Journal of Energy & Technology Vol.25 (2011) 1-9
- [2] S. Arivazhagan , R. Saravanan , S. Renganarayanan ,” Experimental studies on HFC based two-stage half effect vapour absorption cooling system” Applied Thermal Engineering Vol. 26 (2006) 1455–1462
- [3] ulshanSachdeva, Ram Bilash,” Thermodynamic Analysis of a Vapor Absorption System Using Modified Gouy-Stodola Equation” International Journal of Computer, Electrical, Automation, Control and Information Engineering Vol:8, No:12, 2014
- [4] I. Horuz,” A comparison between Ammonia-water and Water-Lithium Bromide solutions in Vapor Absorption Refrigeration Systems” Int. Comm. Heat Mass Transfer, Vol. 25, No. 5, pp. 711-721, 1998
- [5] Abdul Khaliq, and Rajesh Kumar,” Exergy analysis of double effect vapor absorption refrigeration system” Int. J. Energy Res. 2008; Vol.32:161–174
- [6] S.C. Kaushika, AkhileshArora,” Energy and exergy analysis of single effect and series flow double effect water–lithium bromide absorption refrigeration systems” international journal of refrigeration Vol.32 ( 2009 ) 1247 – 1258
- [7] RabahGomri , RiadHakimi,” Second law analysis of double effect vapour absorption cooler system” Energy Conversion and Management Vol.49 (2008) 3343–3348
- [8] S.A. Adewusi, Syed M. Zubair,” Second law based thermodynamic analysis of ammonia–water absorption systems” Energy Conversion and Management Vol. 45 (2004) 2355–2369.
- [9] RabahGomri,” Second law comparison of single effect and double effect vapour absorption refrigeration systems” Energy Conversion and Management Vol. 50 (2009) 1279–1287
- [10] M. Belghazi, A. Bontemps, C. Marvillet,” Experimental study and modelling of heat transfer during condensation of pure fluid and binary mixture on a bundle of horizontal finned tubes” International Journal of Refrigeration Vol.26 (2003) 214–223.
- [11] M.M. Talbi, B. Agnew,” Exergy analysis: an absorption refrigerator using lithium bromide and water as the working Fluids” Applied Thermal Engineering Vol. 20 (2000) 619-630
- [12] E. Kurem,” A comparison between Ammonia-water and Water-Lithium Bromide solutions in vapour absorption heat transformers “In. Comm. Heat Mass Transfer; Vol. 28, No. 3, pp. 421-438, 2001
- [13] Da-Wen Sun,” Comparison of the performances and NH<sub>3</sub>-H<sub>2</sub>O, NH<sub>3</sub>-LiNO<sub>3</sub> and NH<sub>3</sub>-NaSCN VaporAbsorption Refrigeration Systems” Energy Convers. Mgmt Vol. 39, No. 5/6, pp. 357-368, 1998
- [14] Yu.F. Maydanik,” Review Loop heat pipes” Applied Thermal Engineering Vol.25 (2005) 635–657
- [15] Randeep Singh, AliakbarAkbarzadeh , MasatakaMochizuk,” Operational characteristics of a miniature loop heat pipe with flat evaporator” International Journal of Thermal Sciences Vol.47 (2008) 1504–1515
- [16] T.X. Li, R.Z. Wang , L.W. Wang, Z.S. Lu, C.J. Chen,” Performance study of a high efficient multifunction heat pipe type adsorption ice making system with novel mass and heat recovery processes” International Journal of Thermal Sciences Vol.46 (2007) 1267–127
- [17] Yuan-Ching Chiang , Wen-Cheng Kuo , Chia-CheHo , Jen-JieChieh,” Experimental study on thermal performances of heat pipes for air-conditioning systems influenced by magnetic nanofluids, external fields, and micro wicks” International Journal of Refrigeration Vol.43 ( 2014 ) 62 -70
- [18] T.X. Li, R.Z. Wang, L.W. Wang, Z.S. Lu,” Experimental investigation of an innovative dual-mode chemisorption refrigeration system based on multifunction heat pipes” International Journal of Refrigeration 3 1 ( 2 0 0 8 ) 1 1 0 4 – 1 1 1 2
- [19] L. GarousiFarshi a,\* , C.A. Infante Ferreira b, S.M.S. Mahmoudi a, M.A. Rosen,” First and second law analysis of ammonia/salt absorption refrigeration systems” International Journal of Refrigeration Vol. 4 0 ( 2 0 1 4 ) 1 1 1 -1 2 1
- [20] T.X. Li, R.Z. Wang , L.W. Wang, Z.S. Lu, J.Y. Wu,” Influence of mass recovery on the performance of a heat pipe type ammonia sorption refrigeration system using CaCl<sub>2</sub>/activated carbon as compound adsorbent” Applied Thermal Engineering Vol. 28 (2008) 1638–1646
- [21] Z.S. Lu , L.W. Wang, R.Z. Wang,” Experimental analysis of an adsorption refrigerator with mass and heat-pipe heat recovery process” Energy Conversion and Management Vol. 53 (2012) 291–297
- [22] Behrooz M. Ziapour\*, Mohsen Tavakoli,” Performance study on a diffusion absorption refrigeration heat pipe cycle” International Journal of Thermal Sciences Vol.50 (2011) 592-598
- [23] Basant K. Agrawal\*, Munawar N. Karimi,” Thermodynamic performance assessment of a novel waste heat based triple effect refrigeration cycle” International Journal of Refrigeration Vol. 3 5 ( 2 0 1 2 ) 1 6 4 7 -1 6 5 6
- [24] Behrooz M. Ziapour\*, Mohsen Tavakoli,” Performance study on a diffusion absorption refrigeration heat pipe cycle” International Journal of Thermal Sciences 50 (2011) 592-598
- [25] T.S. Jadhav , M.M. Lele,” Theoretical energy saving analysis of air conditioning system using heat pipe heat exchanger for Indian climatic zones” Engineering Science and Technology, an International Journal Vol. 18 (2015) 669-673
- [26] Chengchu Yan , Wenxing Shi , Xianting Li , Shengwei Wang,” A seasonal cold storage system based on separate type heat pipe for sustainable building cooling” Renewable Energy Vol.85 (2016) 880-889
- [27] Matthias H. Buschmann,” Nanofluids in thermosyphons and heat pipes: Overview of recent experiments and modelling approaches” International Journal of Thermal Sciences Vol.72 (2013) 1-17
- [28] P.D. Dunn, D.A. Reay, Heat Pipes, Pergamon Press, Oxford, 1993
- [29] D.Reay, Heat Pipes-Theory, Design and Applications, Butterworth-Heinemann,Oxford, Fifth edition 2006
- [30] Korn, F., “Heat Pipes and its Applications” Project Report 2008 MVK160 Heat and Mass Transport May 07, 2008, Lund, Sweden
- [31] Rajashree, R., Rao, K.S., “A Numerical Study of the Performance of Heat Pipe” Indian Journal of Pure and Applied Mathematics, 21 (1): 95-108, January 1990
- [32] C.P. Arora, Refrigeration and Air Conditioning, Tata Mcgraw-Hill Publishing Company Limited, Delhi, Third Edition, 2009
- [33] AnkitDwivedi, R. S. Mishra,” Thermodynamic Analysis of Heat Pipe Using Ammonia, Water and Ethanol with a View to Being Used in Refrigeration” ISSN 2347 - 3258 International Journal of Advance Research and Innovation, Volume 3, Issue 3 (2015) 498-502
- [34] AnkitDwivedi, R. S. Mishra, Manjunath K,”Optimization of Vapour Absorption System Using Heat Pipes” ISSN: 2321-9653 International Journal for Research in Applied Science & Engineering Technology (IJRASET), Volume 5 Issue VIII, August 2017,634-639.





- [35] <http://hexus.net/tech/news/cooling/81583-fujitsu-thin-loop-heat-pipe-cooler-said-5x-efficient/>
- [36] [https://www.tut.ac.jp/english/schools/faculty/me/post\\_6.html](https://www.tut.ac.jp/english/schools/faculty/me/post_6.html)
- [37] AnkitDwivedi, R. S. Mishra, "Performance Enhancement of Simple Vapour Absorption System Using Loop Heat Pipes" ISSN: 2321-9653 International Journal for Research in Applied Science & Engineering Technology (IJRASET), Volume 6 Issue I, January 2018, 865-873.
- [38] AnkitDwivedi, R. S. Mishra, "Study of Performance Enhancement of Half Effect Vapor Absorption System Using Loop Heat Pipes" ISSN: 2321-9653 International Journal for Research in Applied Science & Engineering Technology (IJRASET), Volume 6 Issue I, January 2018, 1147-1156.
- [39] AnkitDwivedi, R. S. Mishra, "Performance Enhancement Analysis of Double Effect Vapor Absorption System Using Loop Heat Pipes" ISSN: 2321-9653 International Journal for Research in Applied Science & Engineering Technology (IJRASET), Volume 6 Issue I, January 2018, 1523-1533.



10.22214/IJRASET



45.98



IMPACT FACTOR:  
7.129



IMPACT FACTOR:  
7.429



# INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089  (24\*7 Support on Whatsapp)